



NOTES:

1. All service lines shall have a 4-inch inside diameter (ID) or as specified on the plans.
2. All cleanout pipes and fittings shall be the same size and material as the service sewer to which they connect.
3. All cleanout caps shall be threaded plugs.
4. PVC pipe shall conform to SDR-26 specifications.

NOT TO SCALE

| | | |
|---|---------|------|
| Approved by: | | |
|  | | |
| City Of Lathrop City Engineer | | |
| No | Revised | Date |
| | | |
| | | |
| | | |

CITY OF LATHROP
DEPARTMENT OF PUBLIC WORKS

**SANITARY SEWER
LATERAL**



**STANDARD
DETAIL**

Date: **JANUARY 2025**

Drawing No:

S-9